

INSTRUMENT SPECIFICATION SHEET - HYDROGEN SULFIDE GAS MONITORS

GENERAL DATA	1	INSTRUMENT TAG NUMBER				
	2	SERVICE				
	3	P&ID NUMBER				
	4	MANUFACTURER	Detcon			
	5	MATERIAL SOURCE				
	6					
	7					
PROCESS DATA	8	GAS(ES) TO BE DETECTED	H2S			
	9					
	10	CONTAMINANT AND / OR CORROSIVE GASES				
SENSOR DATA	11	SENSOR TAG NUMBER				
	12	MODEL NUMBER	TP-624D			
	13	SENSOR TYPE	S/S (MOS)			
	14	NUMBER OF SENSORS	1			
	15	SENSOR HOUSING MATERIAL	316SS			
	16	CALIBRATED RANGE	0-20/50/100ppm			
TRANSMITTER	17	TRANSMITTER TAG NUMBER				
	18	MODEL NUMBER	TP-624D			
	19	HOUSING NEMA (OR EQUIVALENT) RATING	NEMA 7/4X			
	20	HOUSING MATERIAL	Note 1			
	21	CONDUIT CONNECTION SIZE	3/4" NPT			
	22	OUTPUT SIGNAL, RANGE mA	4-20 mA DC			
	23	MAXIMUM LOOP LOAD, OHMS (@ 24 VDC)	1000 ohms			
	24	OUTPUT SIGNAL, CABLE LENGTH				
	25	SENSOR REPLACEABLE UNDER POWER	YES			
	26	POWER SUPPLY	22.5-28 VDC			
27	DIGITAL DISPLAY	YES				
CONTROLLER UNIT	28	CONTROL UNIT REQUIRED	NO			
	29	CONTROL UNIT TAG NUMBER				
	30	MODEL NUMBER				
	31	NUMBER OF CHANNELS				
	32	NUMBER OF MULTI-CHANNEL RACKS				
	33	LOCATION				
	34	MOUNTING				
	35	HOUSING NEMA (OR EQUIVALENT) RATING				
	36	POWER SUPPLY				
	37	INTEGRAL LOGIC AND LOOP POWER				
	38	WARNING ALARM: LATCHING / UNLATCHING	Note 2			
	39	WARNING ALARM SETPOINT, IN MEASUREMENT UNITS	Note 2			
	40	CRITICAL ALARM SETPOINT, IN MEASUREMENT UNITS	Note 2			
MISC	41	CRITICAL ALARM: LATCHING / UNLATCHING	Note 2			
	42	ELECTRICAL AREA CLASSIFICATION	Class I Division 1 Groups B,C,D			

NOTES:

- 1) Standard Housing Material: Aluminum with epoxy baked finish, Optional: 316 SS
- 2) Alarm relays (2) are field programmable for Latching/Unlatching and Alarm Setpoint; 1 fault relay
- 3) Warranty: Sensor - 10-year conditional, Transmitter - 2-year w/ 5-year fixed fee repair
- 4) Operating Temp. -40°C to +75°C, Operating Humidity 15% to 100% RH non-condensing
- 5) Accuracy/Repeatability is the greater of: ±10.0% of reading or ± 5ppm
- 6) Response Time: T50 < 45 seconds, T80 < 90 seconds
- 7) Plug-in, field replaceable sensor element and transmitter
- 8) Sensor outputs include 4-20 mA , alarm relays (2 w/ LED), fault relay and RS-485 (Modbus RTU)
- 9) Microprocessor-controlled, self-diagnostic transmitter electronics with local Fault LED
- 10) 4-20mA = 0-100% FS, 0mA = Fault, 2mA = In Cal, 22mA = Over-Range