

DETCO INC
MR R MASI
#A-1
3200 RESEARCH FOREST DR
THE WOODLANDS TX 77381

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

JTPX7 September 22, 2003
Gas or Vapor Detection Equipment Listed for Use in Hazardous Locations Certified for Canada

DETCO INC E237249
#A-1 3200 RESEARCH FOREST DR, THE WOODLANDS TX 77381

Class 1, Division 1, Groups B, C and D.
Combustible gas sensors, integral transmitter, IR, followed by -522 or -622.
Combustible gas sensors, remote transmitter IR, followed by -522 or -622, followed by -RT. When used with Remote sensor housing: IR, followed by -522 or -622, followed by -RS.

LOOK FOR LISTING MARK ON PRODUCT

